



This document is scheduled to be published in the  
Federal Register on 03/01/2016 and available online at  
<http://federalregister.gov/a/2016-04434>, and on [FDsys.gov](http://FDsys.gov)

**DEPARTMENT OF LABOR**

*Occupational Safety and Health Administration*

29 CFR Part 1910

Occupational Safety and Health Standards

*CFR Correction*

In Title 29 of the Code of Federal Regulations, Parts 1900 to §1910.999,  
revised as of July 1, 2015, on page 243, in §1910.106, paragraph (a)(14)  
introductory text is reinstated to read as follows:

**§1910.106 Flammable liquids.**

\* \* \* \* \*

(14) *Flashpoint* means the minimum temperature at which a liquid gives off  
vapor within a test vessel in sufficient concentration to form an ignitable  
mixture with air near the surface of the liquid, and shall be determined as  
follows:

\* \* \* \* \*

BILLING CODE 1505-01-P

[FR Doc. 2016-04434 Filed: 2/29/2016 8:45 am; Publication Date: 3/1/2016]